

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER  
MONITORING REQUIREMENTS NOT MET FOR**

**TYLER COUNTY PSD (FKA FRIENDLY PSD), WV3304801**

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 11/1/2019 and 11/30/2019, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

**What should I do?**

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
27, MONITORING, ROUTINE (DBP), MAJOR Missing Required Chlorine Residual Associated With a Bacteriological Sample	11/1/2019 to 11/30/2019

**What happened? What is being done?** (Describe corrective action)

Lab Error. Chlorine was listed on chain of custody. Lab did not include it on the report. Spoke with lab about what info needs to be put on report. I will be checking report more closely in the future.

For more information, please contact Tina LANCASTER at 304-652-1401  
(Contact name) (Phone number)  
 or PO Box 138 Friendly, WV 26146  
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **TYLER COUNTY PSD (FKA FRIENDLY PSD)**

State Water System ID #: WV3304801

Date Distributed: 10/29/2020