

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

BENS RUN INDUSTRIAL PARK WATER SYSTEM, WV9948024

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 1/1/2017 and 12/31/2019, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
03, MONITORING, ROUTINE MAJOR SOC's Sample Results Not Submitted	1/1/2017 to 12/31/2019

What happened? What is being done? (Describe corrective action)

Reporting Error by lab. Samples were collected and there were no issues w/ the water quality. Lab report wasn't completed properly. In the future, lab reports are going to be checked more closely & the lab has been notified as to how report should be filled out.

For more information, please contact Tina Lancaster at 304-652-1401
(Contact name) (Phone number)
Or PO Box 138 Friendly, WV 26146
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **BENS RUN INDUSTRIAL PARK WATER SYSTEM**

State Water System ID #: WV9948024

Date Distributed: 10/29/2020